

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6 DFS/MS/School/2019/SZ/ 2325


Dated: 16/12/19

FIRE SAFETY CERTIFICATE

Certified that the Hamdard Public School located at Talimabad, Sangam Vihar, New Delhi-110080 comprised of in two blocks- School Blk- ground plus three upper floors and Auditorium Blk- stilt plus two upper floors and school first floor interconnect with auditorium first floor was issued FSC by this department vide letter No. F.6/DFS/MS/School/2016/SZ/137 dated 20/01/2016. The said premises was re-inspected by officer concerned of this department on 23/11/2019 in the presence of Mr. Tufil Ahmed (Office Super indent) found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions given below.

Issued on 16/12/19 at New Delhi by

Diary No. 89
Date: 10/1/20
O/o DDE (S)


(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Principal, Hamdard Public School, Talimabad, Sangam Vihar, New Delhi-110080
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."


28/2-24
14-1-2020

Sh. Jait
DDE (South)

✓ HOS through
✓ DDE (2-24)

13/1/2020

DDE/PSB


3/1/2020