

SHARMA & ASSOCIATES

(Govt. Approved Valuer, Architect & Engineer)

HOUSE TAX, INCOME TAX, WEALTH TAX, GIFT DEED, ESTATE DUTY, LIC & BANK LOAN

:: ASSOCIATES ::

Er. Anil Kumar Sharma

MCD LIC NO. SE- 0248

Office: Seat No. P4-C,

Post Office Lane, Tis Hazari

Courts, Delhi-110054

LALIT MOHAN SHARMA

MCD LIC NO. S-2013

Architect/Building Supervisor

(M): 9953279792, 8383073952 & 9818014519

Email Id.: anilkrsharmap4@gmail.com


Date:- 23/07/2025

STRUCTURAL STABILITY CERTIFICATE

Certified that the structural parts of the entire property of "HAMDARD PUBLIC SCHOOL" situated at **Talimabad, Sangam Vihar, New Delhi- 110080**, consisting of Ground floor, First Floor, Second Floor and Third Floors, has been designed on the basis of calculations and satisfied the safety requirements stipulated under clause 18 of the Building Bye-Laws, 1983.

As per Visual inspection of the Building, it is further certified that the structure of the school building is safe and sound for running the school.


24/07/2025
Applicant's signature



23/7/25
ER. ANIL KUMAR SHARMA
STRUCTURE ENGINEER
MCD Lic. No. SE-0248
Ch. No. P-4C, Post Office Lane,
Tis Hazari Courts, Delhi-110054



Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

Known for Excellency in Testing



TEST REPORT

Dated: 29 July 2025

Report No: 32125

Name & contact of Customer: M/s. Hamdard Public School Talimabad Sangam Vihar
New Delhi -110080

Dt. of Receipt: 24.07.2025

Nature of Sample: Said to be Water

Sample ID: Raw Water

Test period: 24- 29 July 2025

Laboratory Mark: SL 32125-250724

S. No	Parameter	Unit	Results	Test Method	Acceptable Limits as per IS: 10500-2012	Conformity of sample Yes / No
1	pH@25°C	--	7.51	IS 3025-Pt 11: 2022	6.5-8.5	Yes
2	Total Hardness as CaCO ₃	mg/L	688.0	IS 3025-Pt 21: 2023	Not more than 200 mg/L	No
3	Calcium as Ca	mg/L	209.60	IS 3025-Pt 40: 2024	Not more than 75 mg/L	No
4	Magnesium as Mg	mg/L	39.85	IS 3025-Pt 46 : 2023	Not more than 30 mg/L	No
5	Total Alkalinity CaCO ₃	mg/L	372.0	IS 3025-Pt 23 : 2023	Not more than 200 mg/L	No
6	Total Dissolved Salts TDS@ 180 °C	mg/L	960.0	IS 3025-Pt 16: 2023	Not more than 500 mg/L	No
7	Chloride Cl	mg/L	207.48	IS 3025-Pt 32: 2019	Not more than 250 mg/L	Yes
8	Turbidity	NTU	1.0	IS 3025-Pt 10:2023	Not more than 1	Yes
9	Odour	Agreeable /Not Agreeable	Agreeable	IS 3025-Pt 5:2018	Agreeable	Yes
10	Iron Fe	mg/L	0.2	IS 3025-Pt 53: 2024	Not more than 0.3 mg/L	Yes
11	Specific Conductivity	µs/cm	1435.0	IS 3025-Pt 14: 2023	-	-

Conditions:

1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi..
4. Retention period of sample is 30 days as per ensuring the report.

Mrs. Pooja

Reviewed by

Mr. Neeraj Katyal

Authorised Signatory

NABL Accredited (TC-15979).

UDYAM-DL-08-0030440

Phones : 9999993311, 9999990481, 9999552799, 9811505398

Email : shankerlaboratories@gmail.com

Website : www.shankerlaboratories.com



Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

Known for Excellency in Testing

TEST REPORT

Dated: 29 July 2025

Report No: 32125

Name & contact of Customer: M/s. Hamdard Public School Talimabad Sangam Vihar
New Delhi -110080

Dt. of Receipt: 24.07.2025

Nature of Sample: Said to be Water

Sample ID: Raw Water

Test period: 24-29 July 2025

Laboratory Mark: SL 32125-250724

S. No	Parameter	Unit	Results	Test Method	Acceptable Limits as per IS: 10500-2012	Conformity of sample Yes / No
1	Color Hz	Hz	1	IS 3025-Pt 4 2021	Not more than 5 Hz	Yes
2	Sulphate SO ₄	mg/L	384.0	IS 3025-Pt 24: Sec 1:2022	Not more than 200 mg/L	No
3	E Coli	Absent/Present	Absent	IS 1622: 1981	Absent	Yes
4	Total Coliform	Absent/Present	Absent	IS 1622: 1981	Absent	Yes

Conditions:

1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi..
4. Retention period of sample is 30 days as per ensuring the report.


Mrs. Pooja
Reviewed by


Mr. Neeraj Katyal
Authorised Signatory

---- End of Report----

UDYAM-DL-08-0030440

Phones : 9999993311, 9999990481, 9999552799, 9811505398

Email : shankerlaboratories@gmail.com

Website : www.shankerlaboratories.com