

Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

Known for Excellency in Testing



TEST REPORT

Dated: 10 October 2024

Report No: 30700

Source: M/s. Hamdard Public School. Gali No.15, Ratia Marg Talimabad, Sangam Vihar, New Delhi-110080

Nature of Sample: Said to be Water

Sample ID: R.O Water

Dt. of Receipt: 04.10.2024

Laboratory Mark: SL 30700


Test period: 04-10 Oct 2024


S. No	Parameter	Results	Test Method	Acceptable Limits as per IS: 10500-2012
1	pH	7.29	3025-Pt 11	6.5-8.5
2	Total Hardness as CaCO ₃ , mg/L	114.0	3025-Pt 21	Not more than 200 mg/L
3	Calcium Ca mg/L	36.80	3025-Pt 40	Not more than 75 mg/L
4	Magnesium Mg mg/L	5.35	3025-Pt 46	Not more than 30 mg/L
5	Total Alkalinity CaCO ₃ , mg/L	62.0	3025-Pt 23	Not more than 200 mg/L
6	Total Dissolved Salts TDS (mg/L)	164	3025-Pt 16	Not more than 500 mg/L
7	Chloride Cl mg/L	18.25	3025-Pt 32	Not more than 250 mg/L
8	Sulphate SO ₄ mg/L	65.60	3025-Pt 24	Not more than 200 mg/L

Remarks: The Water sample conforms to the above specifications of IS 10500.

Conditions:

1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO Shanker Laboratories, New Delhi..


Pooja
Analyst


Neeraj Karwal
Authorised Signatory

--- End of Report ---

NABL Accredited (TC-6113). MSME Reg. No. DL08D0002143

Phones : 9999993311, 9999990481, 9999552799, 9811505398

Email : shankerlaboratories@gmail.com

Website : www.shankerlaboratories.com



Shanker Laboratories

F-277, Flatted Factory Complex, Captain Gaur Marg,
(Near Okhla NSIC Metro Station), Okhla, New Delhi - 110020

Known for Excellency in Testing

TEST REPORT

Dated: 10 October 2024

Report No: 30700

Source: M/s. Hamdard Public School. Gali No.15, Ratia Marg Talimabad, Sangam Vihar, New Delhi-110080

Nature of Sample: Said to be Water

Sample ID: R.O Water

Dt. of Receipt: 04.10.2024

Laboratory Mark: SL 30700

Test period: 04-10 Oct 2024


S. No	Parameter	Results	Test Method	Acceptable Limits as per IS: 10500-2012
1	Colour Hz	1	3025-Pt 4	Not more than 5Hz
2	Odour	Agreeable	3025-Pt 5	Agreeable
3	Turbidity NTU	Nil	3025-Pt 10	Not more than 1
4	Iron Fe mg/L	BDL (DL 0.01mg/L)	3025-Pt 53	Not more than 1 mg/L
5	E Coli	Absent	1622	Absent
6	Total Coliform	Absent	1622	Absent


Remarks: The Water sample conforms to the above specifications of IS 10500.

BDL: Below detection limit. DL: Detection limit.

Conditions:

1. Results given above refer only to the sample supplied.
2. The report is being issued on the specific understanding that Shanker Laboratories will not in any way be involved in any action following the interpretation of the above results.
3. This report shall not be reproduced, except in full, without the written permission of CEO, Shanker Laboratories, New Delhi.


Pooja
Analyst


Neeraj Katyal
Authorised Signatory

---- End of Report ----

NABL Accredited (TC-6113). MSME Reg. No. DL08D0002143

Phones : 9999993311, 9999990481, 9999552799, 9811505398

Email : shankerlaboratories@gmail.com

Website : www.shankerlaboratories.com

MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, CENTRAL ZONE
SHIV MANDIR MARG, LAJPAT NAGAR, NEW DELHI

No.DHO/CNZ/2024/D 1799

Dated: 27/11/2024

HEALTH CERTIFICATE

In further continuation of this, a School Health Certificate was issued vide letter no DHO/CNZ/2021/D-1265 dated 19.10.2023. The school premises were re- inspected by officials of the Public Health Department in the presence of school management, and found to be in sanitary and hygienic condition from a health point of view. The details are as follow:

Name of the school: M/s Hamdard Public School.

Address of School: Gali No.-15, Ratia Marg, Talimabad, Sangam Vihar, New Delhi-110080.

Shifts: ONE Timing: MORNING

No. of Students: Boys:1615 Girls: 1452 Total:-3067

No. of Staff (Teachers): Female: 103 Male: 54 Total: 157


That the accommodation provided for the class rooms as calculated.

- | | | |
|----|--|-----|
| 1. | (A) On floor space is sufficient | Yes |
| | (B) On Cubic space is sufficient | Yes |
| 2. | That the classrooms are well ventilated | Yes |
| 3. | That the classrooms are kept eat and clean | Yes |
| 4. | That the classrooms are well lighted | Yes |

That the building is not in substantial repair in the class of NIL

- | | | |
|----|--|-----------|
| 5. | That the drinking water is wholesome | Wholesome |
| 6. | That the latrines arrangement is adequate and there are sufficient latrines. | |
| 7. | That urinals arrangement is adequate and there are sufficient urinals | |

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety. This certificate is valid for one year from the date of issue.


Dy. Health Officer
Deputy Central Zone
Central Zone, MCD